

Approval Number: 1807514
Test Report: MAT/LAB 169B & 170B



6th August 2018

Axalta Coating Systems Huithwaite UK Limited
Whessoe Road,
Darlington,
County Durham
DL3 0XH

Water Regulations Advisory Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

COATINGS, PAINTS & LININGS - SITE APPLIED PIPE AND FITTINGS COATINGS.

5042

'Acothane DW Cream & Acothane DW Blue to be used with Acothane LV'.

Site applied, cream or blue coloured, two-part polyurethane coatings to be used in conjunction with Acothane LV polyurethane sealer.

Aothane DW cream consists of an amber coloured, liquid activator and cream coloured coating.
Acothane DW Blue consists of an amber coloured, liquid activator and blue coloured coating.
Acothane LV is a cream coloured sealer.

Mix Acothane LV and activator in a weight ratio of 100:48 and then cure for 2 days@3°C.
Mix Acothane DW and activator in a weight ratio of 100:31 and then cure for 7 days@3°C.

For use with water up to 23°C.

These materials are only approved for the mixing and curing conditions that appear on the approval. If the mixing and/or curing conditions are varied from those specified on the approval then the materials are not covered by the scope of the approval.

APPROVAL NUMBER: 1807514
APPROVAL HOLDER: AXALTA COATING SYSTEMS HUITHWAITE UK LIMITED

The Scheme reserves the right to review approval.
Approval 1807514 is valid between July 2018 and July 2023

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme

WRAS MATERIAL APPROVAL - MATERIALS WHICH HAVE PASSED FULL TESTS OF EFFECT ON WATER QUALITY

The material referred to in this letter is suitable for contact with water for domestic purposes. **Approval of this material does not signify the approval of its mechanical or physical properties for any use.**

Manufacturers or applicants may only quote in their sales literature terms which are used in this letter, namely that; 'the material as listed, having passed the tests of effect on water quality, is suitable for use in contact with wholesome water'

This may be abbreviated to 'Water Regulations Advisory Scheme - Approved Material' or 'WRAS Approved Material'.

The scope of an Approval does not extend to rebranded materials unless otherwise agreed by the Scheme.

Use of the WRAS Approved Material Logo

Approval holders may use the WRAS Approved Material logo and make reference to any approval issued by WRAS Ltd. in respect of a particular material or range of materials provided the approval is, and remains valid.

Approval holders are entitled to use the logo on the packing, promotional literature and point of sale advertising Approved Materials.

Modifications to existing Approvals

It is a condition of WRAS Material Approval that NO changes or modifications to the Approved Material, be made without the Approval Holder first notifying WRAS Ltd. Full details of the proposed changes must be provided to the Scheme. Failure to comply with this condition will immediately invalidate a previously granted Approval.

Re-Approval

WRAS will write to you 1 year before the approval expires asking whether you would like to renew it. Please complete the relevant section of the MA3 application form which will be included with the letter and return to WRAS (via e-mail or post).

Please note it is the responsibility of the Approval Holder to ensure the Approval remains valid. WRAS Ltd. accepts no liability for the delay in granting approval where this is caused by circumstances outside of the Scheme's control.